



703.721.3500 | 1800 Limerick Street | Alexandria, Virginia 22314

AlexRenew.com f @ in

October 17, 2024

ITB-25-013: Provision of Preventative, Remedial, and Corrective Maintenance Services for Boilers

Addendum No. 1

Respondents shall acknowledge receipt of this Addendum on the Bid Form. Failure to do so may result in the rejection of the Proposal.

Addendum No.1 to ITB-25-013 consists of following:

- Responses to questions received regarding the solicitation.
- The list of attendees from the optional Information Session held on October 8, 2024.

Response to Respondent's Questions

Q1: I need clarification on page D on page 5. Does this state all refractory to be replaced on the boiler or just point up and seal the refractory?

A1: Re-sealing of the refractory should be included in the PM cost. If refractory needs replacement, it will be handled as a corrective action and Contractor will be reimbursed for the costs of that action separately.

END OF ADDENDUM



Meeting Sign-in

Meeting Title: Pre-bid meeting for ITB 25-013 Preventative Maintenance and Repair of Boilers
Date: 10/8/2024 10:00 AM
Location: AlexRenew Conference Room 300

No.	Name	Company	Phone	E-mail
1	Ben Nichols	CBW	804-393-3763	bnichols@capitalboilerworks.com
2				
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				
16				
17				
18				